

## STANDARD RATINGS FOR DRY TYPE TRANSFORMERS

KVA		Secondary Voltage		
AA	FA	208 V	480 V	4160 V
150	200	●	●	
225	300	●	●	
300	400	●	●	
500	667	●	●	
750	1000	●	●	●
1000	1333	●	●	●
1500	2000	●	●	●
2000	2666	●	●	●
2500	3333	●	●	●
3750	4687		●	●
5000	6250		●	●
7500	9375			●
10000	13333			●

Ratings are for ventilated, 150°C, 115°C, or 80°C transformers with primary voltage 2.4 thru 34.5 kV class. (Note ratings below 500 KVA are not available for 34.5 kV class. Secondary voltages are for either delta or wye connections.)